



QUALITY CONTROL SUB DISTRICT LABORATORY,
KERALA WATER AUTHORITY,
CHADAYAMANGALAM, MADATHARA P O
KOLLAM - 691541

TEST REPORT					
Report No - 2025/QCSDL/CDM/869			Date of Issue: 24.02.2025		
Customer Name & Address			1. Date of Receipt: 21.02.2025		
MARYKUTTY JOSE (PRINCIPAL) A G PUBLIC SCHOOL SWAMI MUKKU PULIPPARA P.O KADAKKAL. Pin:691536 Ph: 8547261007			2. Sampling done by:- CUSTOMER		
			3. Sample Code : 2025/QCSDL/CDM/869		
			4. Source of Sample : OPEN WELL WATER		
			5. Sample Description : DRINKING WATER		
			6. Sample Quantity : 2 Litres		
			7. Test Performing Dates		
			From : 22.02.2025		
Sl No	Characteristics	Unit	Test Method	Maximum Acceptable limits as per IS 10500 -2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013	-	220.6
2	Acidity	(mg/L)	IS 3025 (part 22) -1986 Indicator Method	-
3	Sulphate (as SO ₄)	(mg/L)	IS 3025 (part 24/Sec1) -2022 Turbidity Method using Spectrophotometer	200
4	Fluoride (as F)	(mg/L)	APHA 24th Edition 4500 - F D: SPADNS Method	1.0
5	Iron (as Fe)	(mg/L)	IS 3025 (part 53) -2003 1,10 Phenanthroline Method	1.0	0.00
6	Nitrate (as NO ₃)	(mg/L)	APHA 24th Edition 4500 -NO ₃ B UV Spectrophotometric Screening Method	45	1.82

NB:- 1. The results stated above related only to the sample(s) submitted for testing. 2. This test certificate shall not be reproduced except in full without the written approval of the Laboratory. 3. The results apply to the sample as received. 4. Sample will be retained only for 7 days after reporting the test results.

Authorized by

Name: Snitha .M
Sanitary Chemist

* End of Report *

KWA/QCSDL/CDM/R/19 Issue No. 01 Issue Date : 01.01.2022

Rev. No. 05

Rev. Date : 18.06.2024

Page 1 of 1

SANITARY CHEMIST
QUALITY CONTROL SUB DISTRICT
KERALA WATER AUTHORITY
CHADAYAMANGALAM

No:

1036/25

COMMUNITY HEALTH CENTRE,
NILAMEL, KOLLAM

Dtd. 29/07/2025

HEALTH AND HYGIENIC FITNESS CERTIFICATE

Certified that Sanitation and Hygienic conditions of A.G. Public School
Suzhymuttu Kadakkal

Kadakkal Gramapanchayath, Building number- VIII-729, VIII-815

Prop. Smt Marythaly Jose

is seen satisfactory as per the existing public health rules. This certificate is issued for
obtaining license from Kadakkal Grama Panchayath. This certificate is valid up to
31/03/2026 or to the date on which the Public Health Authority finds that
the unit is unsanitary or unhealthy whichever is earlier. It is *instructed not to store or*
distribute banned plastics.



Health Inspector
CHC Nilamel, Kadakkal Section

HEALTH INSPECTOR I/C

KADAKKAL sec.,

CHC NILAMEL.